

FM Approvals  
 1151 Boston-Providence Turnpike  
 P.O. Box 9102 Norwood, MA 02062 USA  
 T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**MTL7700 Series Shunt Diode Barriers**

AIS/I,II,III/1/ABCDEFG – SCI- 942 Entity; NI/I/2/ABCD/T\* Ta = \*

[I/O] AEx [ia] IIC – SCI-942 Entity; NI/I/2/IIC/T\* Ta = \*

**Special Condition of Use:**

1. The MTL7700 Series barriers shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Entity Parameters:

Single channel barrier to one device with ground return:

BARRIER MODEL Terminals	Voc or Uo (V)	Isc or Io (mA)	Po (W)	Ca or Co (µF)	La or Lo (mH)	La/Ra or Lo/Ro (µH/Ω)	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7706+ 3 & 4	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7710+/- 3 & 4	10	200	0.5	3.0	0.91	74	T4	60°C
MTL7715+/- 3 & 4	15	150	0.56	0.58	1.45	66	T4	60°C
MTL7715P+/- 3 & 4	15	291	1.09	0.58	0.33	28	T4	60°C
MTL7722+/- 3 & 4	22	147	0.81	0.165	1.45	45	T4	60°C
MTL7728+/-/ac 3 & 4	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7728P+/- 3 & 4	28	119	0.83	0.083	2.51	44	T4	60°C

Dual, three or four channel barrier, each channel to separate devices, with separate ground returns:

BARRIER MODEL Terminals	Voc or Uo (V)	Isc or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2/ Zone 2 Temp. code	
							T*	Ta*
MTL7707+ 3 & GND	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7707+ 4 & GND	28	0	—	0.083	—	—	T4	60°C
MTL7707P+ 4 & GND	28	0	—	0.083	—	—	T4	60°C
MTL7755ac 3 & GND or 4 & GND	3	300	0.225	100	0.46	145	T4	65°C
MTL7756ac 3 & GND or 4 & GND or 7 & GND	3	300	0.225	100	0.46	145	T4	65°C
MTL7758+/- 3 & GND or 4 & GND	7.5	750	1.4	11.1	0.07	26	T4	60°C
MTL7760ac 3 & GND or 4 & GND	10	200	0.5	3.0	0.91	74	T4	60°C
MTL7761ac 3 & GND or 4 & GND	9	100	0.225	4.9	3.72	163	T4	60°C
MTL7761Pac 3 & GND or 4 & GND	9	26	0.058	4.9	56	613	T4	60°C
MTL7764+/- 3 & GND or 4 & GND	12	12	0.036	1.41	240	1000	T4	60°C
MTL7764ac 3 & GND or 4 & GND	12	12	0.036	1.41	240	1000	T4	60°C
MTL7765ac 3 & GND or 4 & GND	15	150	0.56	0.58	1.45	66	T4	60°C
MTL7766ac 3 & GND or 4 & GND	12	80	0.24	1.41	5.8	151	T4	60°C
MTL7766Pac 3 & GND or 4 & GND	12	157	0.471	1.41	1.47	78	T4	60°C

BARRIER MODEL Terminals	Voc or Uo (V)	Isc or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7767+/- 3 & GND or 4 & GND	15	150	0.56	0.58	1.45	66	T4	60°C
MTL7778ac 3 & GND or 4 & GND	28	47	0.33	0.083	16	107	T4	60°C
MTL7779+/- 3 & GND or 4 & GND	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7787+/- 3 & GND	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7787+/- 4 & GND	28	0	—	0.083	—	—	T4	60°C
MTL7787P+/- 3 & GND	28	119	0.83	0.083	2.51	44	T4	60°C
MTL7787P+/- 4 & GND	28	0	—	0.083	—	—	T4	60°C
MTL7788+/- 3 & GND	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7788+/- 4 & GND	10	200	0.5	3.0	0.91	74	T4	60°C
MTL7788R+/- 3 & GND	28	93	0.65	0.083	4.2	56	T4	60°C
MTL7788R+/- 4 & GND	10	200	0.5	3.0	0.91	74	T4	60°C
MTL7789+/- 3 & GND or 7 & GND	28	46.5	0.33	0.083	16	106	T4	60°C
MTL7789+/- 4 & GND or 8 & GND	28	0	—	0.083	—	—	T4	60°C
MTL7796+/- 3 & GND	26	87	0.56	0.1	4.91	64	T4	60°C
MTL7796+/- 4 & GND	20	51	0.26	0.22	13	136	T4	60°C

Dual, three or four channel barrier, two channels to same device, with or without ground returns:

BARRIER MODEL Terminals	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2 / Zone 2 Temp. code	
							T *	Ta *
MTL7707+ 3 & 4	29.4	93	0.65	0.071	4.2	56	T4	60°C
MTL7741 3 & 4	10	19	0.039	2.86	96	742	T4	60°C
MTL7742 3 & 4	10	19	0.039	2.86	96	742	T4	60°C
MTL7743 3 & 4 or 7 & 8	10	19	0.039	2.86	96	742	T4	60°C
MTL7744 3 & 4 or 7 & 8	10	19	0.039	2.86	96	742	T4	60°C
MTL7745 3 & 4	10	19	0.039	2.86	96	742	T4	60°C
MTL7755ac 3 & 4	6	600	0.45	40	0.13	69	T4	65°C
MTL7756ac 3 & 4 or 4 & 7 or 3 & 7	6	600	0.45	40	0.13	69	T4	65°C
MTL7758+/- 3 & 4	7.9	1500	2.8	8.8	0.02	10	T4	60°C
MTL7760ac 3 & 4	10	400	1.0	3.0	0.2	35.6	T4	60°C
MTL7761ac 3 & 4	18	200	0.45	0.31	0.91	62	T4	60°C
MTL7761Pac 3 & 4	18	52	0.115	0.31	14	236	T4	60°C
MTL7764+/- 3 & 4	13	24	0.072	1.0	61	360	T4	60°C
MTL7764ac 3 & 4	24	24	0.072	0.125	61	360	T4	60°C
MTL7765ac 3 & 4	15	300	1.12	0.58	0.32	31.6	T4	60°C
MTL7766ac 3 & 4	24	160	0.48	0.125	1.47	58	T4	60°C
MTL7766Pac 3 & 4	24	314	0.942	0.125	0.34	29	T4	60°C

BARRIER MODEL Terminals	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2 / Zone 2 Temp. code	
							T *	Ta *
MTL7767+/- 3 & 4	15	300	1.125	0.58	0.32	22	T4	60°C
MTL7778ac 3 & 4	28	93	0.654	0.083	4.2	56	T4	60°C
MTL7787+/- 3 & 4	29.4	93	0.65	0.071	4.2	56	T4	60°C
MTL7787P+/- 3 & 4	28.5	119	0.835	0.078	2.51	44	T4	60°C
MTL7788+/- 3 & 4	28	294	0.92	0.083	0.33	25	T4	60°C
MTL7788R+/- 3 & 4	28	294	0.92	0.083	0.33	25	T4	60°C
MTL7789+/- 3 & 4 or 7 & 8	28	46.5	0.33	0.083	16	106	T4	60°C
MTL7796+/- 3 & 4	26.4	138	0.81	0.096	1.94	34	T4	60°C

Three channel barrier, three channel to same device, with or without ground return:

BARRIER MODEL Terminals	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7756ac 3 & 4 & 7	6	900	0.675	40	0.06	44	T4	65°C

Four channel barrier, four channel to same device, with or without ground return:

BARRIER MODEL Terminals	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co ( $\mu$ F)	La or Lo (mH)	La/Ra or Lo/Ro ( $\mu$ H/ $\Omega$ )	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7743 3 & 4 & 7 & 8	10	38	0.078	2.73	25	184	T4	60°C
MTL7744 3 & 4 & 7 & 8	10	38	0.078	2.73	25	184	T4	60°C
MTL7789+/- 3 & 4 & 7 & 8	28	93	0.65	0.083	4.2	56	T4	60°C

**Equipment Ratings:**

Associated intrinsically safe apparatus with connections for Class I, II and III, Division 1, applicable Groups A, B, C, D, E, F and G; AEx [ja] IIC per "Entity" requirements in accordance with installation drawing SCI-942 Issue 5; nonincendive for installation in Class I, Division 2, Groups A, B, C and D, T4 at Ta = 60°C or 65°C; Class I, Zone 2, Group IIC, T4 at Ta = 60°C or 65°C hazardous (classified) indoor locations

**And**

**MTL7700 Series Shunt Diode Barriers**

AIS/I,II,III/1/CDEFG – SCI-942 Entity; NI/II/2/ABCD/T \* Ta = \*

[I/O] AEx [ja] IIB – SCI-942 Entity; NI/II/2/IIC/T \* Ta = \*

*Special Condition of Use:*

1. The MTL7700 Series barriers shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Entity Parameters:

**Single channel barrier to one device with ground return:**

BARRIER MODEL Terminals	Voc or Uo (V)	Isc or Io (mA)	Po (W)	Ca or Co (µF)	La or Lo (mH)	La/Ra or Lo/Ro (µH/Ω)	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7729P+/- 3 & 4	28	170	1.19	0.65	5.65	127	T4	60°C

**Dual, three or four channel barrier, each channel to separate devices, with separate ground returns:**

BARRIER MODEL Terminals	Voc or Uo (V)	Isc or Io (mA)	Po (W)	Ca or Co (µF)	La or Lo (mH)	La/Ra or Lo/Ro (µH/Ω)	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7707P+ 3 & GND	28	171	1.2	0.65	5.34	125	T4	60°C

**Dual, three or four channel barrier, two channels to same device, with or without ground return:**

BARRIER MODEL Terminals	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co (µF)	La or Lo (mH)	La/Ra or Lo/Ro (µH/Ω)	Division 2/ Zone 2 Temp. code	
							T *	Ta *
MTL7707P+ 3 & 4	29.4	171	1.2	0.587	5.34	125	T4	60°C
MTL7779+/- 3 & 4	28.3	186	1.3	0.636	4.1	108	T4	60°C

**Equipment Ratings:**

Associated intrinsically safe apparatus with connections for Class I, II and III, Division 1, applicable Groups C, D, E, F and G; AEx [ia] IIB per "Entity" requirements in accordance with installation drawing SCI-942 Issue 5; nonincendive for installation in Class I, Division 2, Groups A, B, C and D, T4 at Ta = 60°C or 65°C; Class I, Zone 2, Group IIC, T4 at Ta = 60°C or 65°C hazardous (classified) indoor locations

**And**

**MTL7798 Power Feed Module**

NI/II/2/ABCD/T4 Ta = 60°C; NI/II/2/IIC/T4 Ta = 60°C

*Special Condition of Use:*

1. The MTL7798 Power Feed Module shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
2. The MTL7798 Power Feed Module may be installed with MTL7700 Series Shunt Diode Barriers as auxiliary nonincendive apparatus.

**Equipment Ratings:**

Nonincendive apparatus for installation in Class I, Division 2, Groups A, B, C and D, T4 at Ta = 60°C or 65°C; Class I, Zone 2, Group IIC, T4 at Ta = 60°C or 65°C hazardous (classified) indoor locations

**Approved for:**

Measurement Technology Limited  
Power Court, Luton  
Bedfordshire, England LU1 3JJ

This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3610	1999
Class 3611	1999
Class 3810	1989
Including Supplement #1	1995


Original Project ID: 3010737

FM Approval Granted: October 8, 2001

Subsequent Revision Reports / Date FM Approval Amended

3012746	December 28, 2001
3013001	May 2, 2002
3014491	July 4, 2002


FM Global Technologies LLC

A handwritten signature in cursive script, reading "David W. Styracula".

David W. Styracula  
Technical Team Manager

10-4-02  
Date




Ckd									
Cl									
No									
Modification	MTL7741, 42, 43, 44, 45 & 78ac added. Extra sheet added.								
Drn									
Date	6.02	SM							
Is	5								
 <b>MEASUREMENT TECHNOLOGY LTD</b> Luton, England Copyright Reserved - Written Permission to Copy Should be Obtained									
Ckd									
Cl									
No									
Modification	Reference to Note 9 added.								
Drn									
Date	8.01	CMB							
Is	1								
Is	2								
Is	3								
Is	4								
Modification	See sheets 4 & 5.								
Drn									
Date	2.02	SM							
Is	4								
Modification	MTL7706+, 07+, 07P+, 56+/-, 88+/- added. Extra sheets added.								

Dimensions in mm

Do Not Scale

Third Angle Projection




System Certificate No.		Scale	N/A
Certifying Authority: FM		Sheet	1 of 10
Title		Drg. No.	
MTL7700 SERIES BARRIER CONTROL DRAWING		SCI-942	

Dimensions in mm

Do Not Scale

Third Angle Projection

Is	1	8.01	CMB				
Date	2	10.01	CMB	See all other sheets.			
Is	3	11.01	CMB	See sheets 4 & 5.			
Date	4	2.02	SM	See sheet 1.			
Is	5	6.02	SM				
Date							
Drn							
Modification							
No							
Cl							
Ckd							



MEASUREMENT TECHNOLOGY LTD  
Luton, England  
Copyright Reserved - Written Permission to Copy Should be Obtained

**CONFIGURATIONS:**

- a) Single channel barrier to one device with ground return
- b) Dual channel barrier, each channel to separate devices with separate ground returns
- c1) Dual channel barrier, first channel (power channel on diode return barriers) to separate device with separate ground return
- c2) Dual channel barrier, second channel (diode return channel on diode return barriers) to separate device with separate ground return
- d) Dual channel barrier, both channel to the same device with or without ground return
- e) Three channel barrier, each channel to separate devices with separate ground returns
- f) Three channel barrier, two channels to same device with or without ground return and one channel to separate device with separate ground return
- g) Three channel barrier, three channels to same device with or without ground return
- h) 1st, 2nd, 3rd, or 4th channel of a four channel barrier, each channel to separate devices with separate ground returns.
- j) Four channel barrier, all channels to same device with or without ground return.
- k) Four channel barrier, channels 1 and 2 or channels 3 and 4 to same device with or without ground return.

System Certificate No.		Scale	N/A
Certifying Authority: FM		Sheet	2 of 10
Title		Drg. No.	
MTL7700 SERIES BARRIER CONTROL DRAWING		SCI-942	



Is	1	8.01	CMB				
Date	2	10.01	CMB	Note 9 added.			
Is	3	11.01	CMB	Note 10 added.			
Date	4	2.02	SM	See sheet 1.			
Is	5	6.02	SM				
Date							
Drn							
Modification							
No							
Cl							
Ckd							

**Note 7**

For guidance on the installation refer to ANSI/ISA RP2.6 "Wiring Practices for Hazardous (Classified) Locations Instruments, Part I: Intrinsic Safety" and the National Electrical Code (ANSI/NFPA 70).

**Note 8**

Entity parameters for barriers listed in the parameters table must be used to determine the suitability of the barrier for connection to hazardous location apparatus. The following must be observed:

$V_{oc} \text{ or } V_t (U_o) \leq V_{max} (U_i)$

$I_{sc} \text{ or } I_t (I_o) \leq I_{max} (I_i)$

$P_o \leq P_i$

$C_a (C_o) \geq C_{cable} + C_i$

$L_a (L_o) \geq L_{cable} + L_i \text{ or } L_a/R_a (L_o/R_o) \geq L_{cable}/R_{cable} \text{ and } L_a/R_a (L_o/R_o) \geq L_i/R_i$

**Note 9**

Certain barriers are not permitted as associated apparatus for Div 1 Groups A,B or Zones 0,1 Group IIC. Refer to entries with asterisks in the following table.

**Note 10**

When fitted in a Safe Area, the barriers may be used at the same maximum ambient temperature as when used in Division 2 or Zone 2.

**WARNING:**

The following precautions must be taken when MTL7700 Series Shunt Diode Barriers are installed in Division 2 or Zone 2 Hazardous locations:

- i Barriers must not be fitted to or removed from the DIN rail unless power is off or the location is known to be free of flammable vapors.
- ii Plug in terminals on non-hazardous (Safe) side of the barriers as well as the bus power terminal jumper of barriers fitted with the bus power feature, must not be inserted or removed unless power is off or the location is known to be free of flammable vapors.

MEASUREMENT TECHNOLOGY LTD  
Luton, England  
Copyright Reserved - Written Permission to Copy Should be Obtained

System Certificate No.		Scale	N/A
Certifying Authority: FM		Sheet	4 of 10
Title MTL7700 SERIES BARRIER CONTROL DRAWING		Drg. No.	SCI-942

Is	1	8.01	Drn		Modification	No	CI	Ckd		No	CI	Ckd
2	10.01	CMB			Right-hand column was mH/Ω.							
3	11.01	CMB			MTL7715P+/- added.							
4	2.02	SM			See sheet 1.							

**MEASUREMENT TECHNOLOGY LTD**

Luton, England

Copyright Reserved - Written Permission  
to Copy Should be Obtained

Dimensions in mm

Do Not Scale

Third Angle Projection

BARRIER Model Terminals	C O N F I G	Voc or Uo (V)	Isc or Io (mA)	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co (μF) AB(IIC)/CE(IIB)/DFG(IIA)	La or Lo (mH) AB(IIC)/CE(IIB)/DFG(IIA)	La/Ra or Lo/Ro (μH/Ω) AB(IIC)/CE(IIB)/DFG(IIA)
MTL7706+ 3 & 4	a	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7707+ 3 & GND	c1	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7707+ 4 & GND	c2	28	0	—	—	—	0.083/0.65/2.15	—	—
MTL7707+ 3 & 4	d	—	—	29.4	93	0.65	0.071/0.587/1.91	4.2/12.6/33.6	56/210/444
MTL7707P+ 3 & GND	c1	28	171	—	—	1.2	*0.65/2.15	*5.34/10.73	*125/256
MTL7707P+ 4 & GND	c2	28	0	—	—	—	0.083/0.65/2.15	—	—
MTL7707P+ 3 & 4	d	—	—	29.4	171	1.2	*0.587/1.91	*5.34/10.73	*125/256
MTL7710+/- 3 & 4	a	10	200	—	—	0.5	3.0/20/100	0.91/2.72/7.25	74/310/627
MTL7715+/- 3 & 4	a	15	150	—	—	0.56	0.58/3.55/14	1.45/7.22/14	66/263/544
MTL7715P+/- 3 & 4	a	15	291	—	—	1.09	0.58/3.55/14.0	0.33/0.99/2.64	28/140/280
MTL7722+/- 3 & 4	a	22	147	—	—	0.81	0.165/1.14/4.2	1.45/7.22/14	45/180/373
MTL7728+/-/ac 3 & 4	a	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7728P+/- 3 & 4	a	28	119	—	—	0.83	0.083/0.65/2.15	2.51/7.53/20	44/168/354

\* Not permitted for Groups A/B(IIC)

System Certificate No.

Scale N/A

Certifying Authority: FM

Sheet 5 of 10

Title  
MTL7700 SERIES BARRIER CONTROL DRAWING

Drg. No.  
SCI-942

Is	Date	Drn	Modification	No	Cl	Ckd
4	2.02	SM	See sheet 1.			
5	6.02	SM	See sheet 1.			
<p><b>MEASUREMENT TECHNOLOGY LTD</b> Luton, England</p> <p>Copyright Reserved - Written Permission to Copy Should be Obtained</p>						

BARRIER Model Terminals	C O N F I G	Voc or Uo (V)	Isc or Io (mA)	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co (μF) AB(IIC)/CE(IIB)/DFG(IIA)	La or Lo (mH) AB(IIC)/CE(IIB)/DFG(IIA)	La/Ra or Lo/Ro (μH/Ω) AB(IIC)/CE(IIB)/DFG(IIA)
MTL7729P+/- 3 & 4	a	28	170	—	—	1.19	* /0.65/2.15	* /5.65/11.34	* /127/260
MTL7741 3 & 4	d	—	—	10	19	0.039	2.86 /20.0/100	96 /365/696	742/1900/1900
MTL7742 3 & 4	d	—	—	10	19	0.039	2.86 /20.0/100	96 /365/696	742/1900/1900
MTL7743 3 & 4 or 7 & 8	k	—	—	10	19	0.039	2.86 /20.0/100	96 /365/696	742/1900/1900
MTL7743 3,4,7 & 8	j	—	—	10	38	0.078	2.73 /19.9/100	25 /91/193	184/694/1323
MTL7744 3 & 4 or 7 & 8	k	—	—	10	19	0.039	2.86 /20.0/100	96 /365/696	742/1900/1900
MTL7744 3,4,7 & 8	j	—	—	10	38	0.078	2.73 /19.9/100	25 /91/193	184/694/1323
MTL7745 3 & 4	d	—	—	10	19	0.039	2.86 /20.0/100	96 /365/696	742/1900/1900
MTL7755ac 3 & GND or 4 & GND	b	3	300	—	—	0.225	100/1000/1000	0.46/1.37/3.66	145/722/1442
MTL7755ac 3 & 4	d	—	—	6	600	0.45	40/1000/1000	0.13/0.39/1000	69/206/548

System Certificate No.		Scale	N/A
Certifying Authority: FM		Sheet	6 of 10
Title MTL7700 SERIES BARRIER CONTROL DRAWING		Drng. No.	SCI-942

\* Not permitted for Groups A/B(IIC)







Is	Date	Drn	Modification	No	Cl	Ckd
1	8.01	CMB				
2	10.01	CMB	Right-hand column was mH/Ω.			
3	11.01	CMB	See sheets 4 & 5.			
4	2.02	SM	See sheet 1.			

MEASUREMENT TECHNOLOGY LTD  
Luton, England  
Copyright Reserved - Written Permission to Copy Should be Obtained

Dimensions in mm

Do Not Scale

Third Angle Projection

BARRIER Model Terminals	C O N F I G	Voc or Uo (V)	Isc or Io (mA)	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co (μF)	La or Lo (mH)	La/Ra or Lo/Ro (μH/Ω)
MTL7778ac 3 & GND or 4 & GND	b	28	47	—	—	0.33	0.083/0.65/2.15	16/62/130	107/398/789
MTL7778ac 3 & 4	d	—	—	28	93	0.654	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7779+/- 3 & GND or 4 & GND	b	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7779+/- 3 & 4	d	—	—	28.3	186	1.3	* /0.63/2.09	* /4.1/7.9	* /108/217
MTL7787+/- 3 & GND	c1	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7787+/- 4 & GND	c2	28	0	—	—	—	0.083/0.65/2.15	—	—
MTL7787+/- 3 & 4	d	—	—	29.4	93	0.65	0.071/0.587/1.91	4.2/12.6/33.6	56/210/444
MTL7787P+/- 3 & GND	c1	28	119	—	—	0.835	0.083/0.65/2.15	2.51/7.53/20	44/168/354
MTL7787P+/- 4 & GND	c2	28	0	—	—	—	0.083/0.65/2.15	2.51/7.53/20	44/168/354
MTL7787P+/- 3 & 4	d	—	—	28.5	119	0.835	0.078/0.627/2.05	2.51/7.53/20	44/168/354

System Certificate No.	Scale N/A
Certifying Authority: FM	Sheet 9 of 10
Title MTL7700 SERIES BARRIER CONTROL DRAWING	Drg. No. SCI-942

Is	Date	Drn	Modification	No	Cl	Ckd	Drn	Modification	No	Cl	Ckd
5	6.02	SM	See sheet 1.								

MEASUREMENT TECHNOLOGY LTD  
Luton, England

Copyright Reserved - Written Permission  
to Copy Should be Obtained

Dimensions in mm

Do Not Scale

Third Angle Projection

BARRIER Model Terminals	C O N F I G	Voc or Uo (V)	Isc or Io (mA)	Vt or Uo (V)	It or Io (mA)	Po (W)	Ca or Co (μF) AB(IIC)/CE(IIB)/DFG(IIA)	La or Lo (mH) AB(IIC)/CE(IIB)/DFG(IIA)	La/Ra or Lo/Ro (μH/Ω) AB(IIC)/CE(IIB)/DFG(IIA)
MTL7788+/- MTL7788R+/- 3 & GND	c1	28	93	—	—	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7788+/- MTL7788R+/- 4 & GND	c2	10	200	—	—	0.5	3.0/20/100	0.91/2.72/7.25	74/310/627
MTL7788+/- MTL7788R+/- 3 & 4	d	—	—	28	294	0.92	0.083/0.65/2.15	0.33/0.99/2.64	25/124/253
MTL7789+/- 3 & GND or 7 & GND	h	28	46.5	—	—	0.33	0.083/0.65/2.15	16/63/133	106/393/781
MTL7789+/- 4 & GND or 8 & GND	h	28	0	—	—	0	0.083/0.65/2.15	—	—
MTL7789+/- 3 & 4 & 7 & 8	j	—	—	28	93	0.65	0.083/0.65/2.15	4.2/12.6/33.6	56/210/444
MTL7789+/- 3 & 4 or 7 & 8	k	—	—	28	46.5	0.33	0.083/0.65/2.15	16/63/133	106/393/781
MTL7796+/- 3 & GND	c1	26	87	—	—	0.56	0.1/0.77/2.6	4.91/20/40	64/239/505
MTL7796+/- 4 & GND	c2	20	51	—	—	0.26	0.22/1.41/5.5	13/51/108	136/501/1014
MTL7796+/- 3 & 4	d	—	—	26.4	138	0.81	0.096/0.74/2.48	1.94/8.5/16	34/136/282

System Certificate No.		Scale	N/A
Certifying Authority: FM		Sheet	10 of 10
Title MTL7700 SERIES BARRIER CONTROL DRAWING		Drn. No.	SCI-942