

The manufacturer may use the mark:



Revision 1.1 August 16, 2018 Surveillance Audit Due September 1, 2019

# Certificate / Certificat Zertifikat / 合格証

ASC 1605108 C001

exida hereby confirms that the:

381 3-Way NC Solenoid Valves
ASCO, L.P.
Florham Park, NJ - USA

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2<sub>H</sub> Device

PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application

## Safety Function:

The Valve will move to the designed safe position when deenergized / energized within the specified safety time.

# Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.





ANSI Accredited Program
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004



Evaluating Assessor

Certifying Assessor

# Certificate / Certificat / Zertifikat / 合格証

ASC 1605108 C001

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2<sub>H</sub> Device

PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application

#### Systematic Capability:

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with these products must not be used at a SIL level higher than stated.

#### **Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2<sub>H</sub>.

#### **Versions:**

Valve Type	Description and Application
381 DTT	Series 381 3-Way NC Solenoid Valve, De-energized to Trip (DTT)
381 ETT	Series 381 3-Way NC Solenoid Valve, Energized to Trip (ETT)
Options	Optional JS2D Junction Box and Coils

## IEC 61508 Failure Rates in FIT1

Device		λ <sub>SU</sub>	$\lambda_{ extsf{DD}}$	$\lambda_{ extsf{DU}}$
381 3-Way NC, DTT, Low Power Coil		209	0	220
381 3-Way NC, ETT, Low Power Coil		31	0	346
381 3-Way NC, DTT, 9-16W Coil		508	0	220
381 3-Way NC, ETT, 9-16W Coil		31	0	424
381 3-Way NC, DTT, Class H 16-30W Coil	0	938	0	220
381 3-Way NC, ETT, Class F or H 16-30W Coil	0	31	0	517

<sup>&</sup>lt;sup>1</sup> FIT = 1 failure / 10<sup>9</sup> hours

#### SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: ASC 16/05-108 R002 V1R1 (or later)

Safety Manual: V9629R8 (or later)

381 3-Way NC Solenoid Valves



80 N Main St Sellersville, PA 18960